

### Instructions:

1. The Major Connections Certifier is responsible of conducting the on-maintenance Inspection, (this form can be used as a guideline).
2. The Major Connections Certifier must be in receipt of all relevant documentations as per the Unitywater Accreditation and Certification Manual;
3. The meeting **must** be attended by the following, in addition to the Major Connections Certifier:
  - a. Construction Certifier;
  - b. Contractor's Supervisor; and or
  - c. Sub-Contractor – if not the Principal Contractor.
4. Before proceeding to the inspection of water meters, the Registered Major Connections Certifier must be in receipt of a completed Unitywater Water Meter Register and Property Conditions document. The Registered Major Connections Certifier must confirm each meter is correctly recorded against the lot it is installed to service.
5. The CCTV Inspection report has been reviewed and accepted by the Major Connection Certifier and the CCTV video survey has been undertaken within two (2) months of the On-Maintenance inspection.
6. Do not proceed with On-Maintenance Inspection unless all Inspection Prerequisites have been met (Table 2).

Unitywater Connection Approval Ref No: .....	SP Plan: .....
Development Estate Name / Street Name: .....	Stage: ..... Total Number of Lots: .....
Construction Certifier Name / Accreditation No ..... Phone No: .....	
On Maintenance Inspection Date: .....	

**Table 1 - On Maintenance Inspection Attendance Record**

Stakeholder Title	Name	Phone	Signature
Major Connections Certifier			
Construction Certifier			
Contractor's Supervisor			
Sub-Contractor (if relevant)			
Unitywater Officer (if attending)			

### Inspection Guideline:

**Table 2 – On-Maintenance Inspection Prerequisite**

Compliant			
Yes	No	N/A	
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Survey Pegs are installed (survey pegs and not stake markers).
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Water mains are pressurised to enable connection of water meters to be confirmed.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Copy of As-Constructed drawing submitted to Unitywater. (6.1.1.3 Pr10255)
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Copy of completed Water Meter Register and Property Conditions submitted to Unitywater. (6.1.1 Pr10255)
			Unitywater Office Use Compliant: Yes <input type="checkbox"/> No <input type="checkbox"/>

**Table 3 – Water Reticulation Valves**

Compliant			
Yes	No	N/A	
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	As constructed accurately represents physical assets inspected and relevant items below are compliant with Code or Approved plan/variation. (6.1.1.3 Pr10255)
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Water main alignment meets Unitywater specifications. (5.4 WSA03)
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Valve spindle grub screws are tight and that valve spindles are fixed to valves.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Top of valve spindles are 100mm to 225mm below valve box lid. (SEQ-WAT-1301-1)
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Valve spindle is centrally located in box.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Only detectable tape shall be used. Detectable tape should be laid on top of the pipe embedment to form a continuous connection between valves and/or hydrants. Tape is to be accessible within valve shroud.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Valve body has been wrapped in manufacturer approved polythene blue sleeving (visible in valve box).
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shroud is 225mm in diameter and extends to the top of surround cover inside the valve box. (SEQ-WAT-1301-1)
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Valve and valve box are void of mud and dirt (to bottom of shroud).
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Valve box lids have been built to trafficable (pavement or constructed driveway) or non-trafficable specification as required per 8.10.4 WSA03
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Valve box lid is the correct colour as per colour codes table. (SEQ-WAT-1300-1)

Compliant			<b>Table 3 – Water Reticulation Valves - Continued</b>
Yes	No	N/A	
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Valve box is level with the FSL and poses no risk as a trip hazard. (8.10.4 WSA03)
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Longest axes of valve boxes are aligned with the water main alignment. (SEQ-WAT-1301-1)
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Valve brass kerb markers are installed flush with the face of kerb and painted as specified on SEQ-WAT-1300-1, or if there is no kerb marker post constructed as per SEQ-SEW-1301-1.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Pavement marker, kerb marker and brass marker (or marker post where applicable) are all in line with valve box lid. (SEQ-WAT-1300-1)

Unitywater  
 Office Use  
 Compliant:    Yes                       No

Compliant			<b>Table 4 – Hydrants</b>
Yes	No	N/A	
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	As constructed accurately represents physical assets inspected and relevant items below are compliant with Code or Approved plan/variation. (6.1.1.3 Pr10255)
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Hydrant locations match SEQ Code requirements. (8.8 WSA03)
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	The water main alignment meets Unitywater requirements, measured by hydrant location offset from boundary. (9.1 & 8.8.9 WSA03)
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Hydrant brass kerb markers are installed flush with the face of kerb and painted as specified on SEQ-WAT-1300-1, or if there is no kerb marker post constructed as per SEQ-SEW-1301-1.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Blue RRPMS are installed (100mm offset from centre of the road) and in line with the hydrant and brass kerb marker. (SEQ-WAT-1300-1)
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Thermoplastic reflective directional arrow installed (Golden yellow - AS2700 Y14). (SEQ-WAT-1300-1)
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Blue RRPM, reflective directional arrow, kerb marker and brass marker (or marker post where applicable) are all in line with hydrant box lid. (SEQ-WAT-1300-1)
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Hydrants and hydrant boxes are void of mud and dirt.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Hydrant risers are DN 100. (8.8.7 WSA03)
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Marker tape should be laid on top of the pipe embedment to form a continuous connection between valves and/or hydrants. Tape to be accessible in the hydrant shroud.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Hydrant tee and riser body wrapped in manufacturer approved polythene blue sleeving (visible in hydrant box).
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Hydrant shroud is diameter 225mm and extends to the top of the surround cover inside hydrant box. (SEQ-WAT-1302-1)
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Top of hydrant lugs/claws are 100mm to 225mm below hydrant box lid. (SEQ-WAT-1302-1)
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Hydrant is centrally located in hydrant box.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Hydrant lugs/claws are aligned parallel with the main alignment. (SEQ-WAT-1302-1 E Note 10)
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Temporary hydrant is installed with the hydrant boxes' long axes at 90deg to the water main alignment (SEQ-WAT-1302-1)
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Temporary hydrants to be removed with live connection works are not identified with a marker of any kind.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Hydrant box lids have been constructed to trafficable (pavement or constructed driveway) or non-trafficable specification as required as per 8.8.9 WSA03.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	The hydrant box lid is the correct colour as specified in SEQ-WAT-1300-1.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Hydrant box is level with the FSL and poses no risk as a trip hazard. (8.8.9 WSA03)
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Longest axes of hydrant boxes are aligned with the water main alignment. (SEQ-WAT-1302-1)
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Hydrant box surrounds installed when hydrants are located in concrete pathway/constructed driveway or road pavement. (8.8.9 WSA03)

Unitywater  
 Office Use  
 Compliant:    Yes                       No

Compliant			<b>Table 5 – Water Service Conduits and Water Main Road Crossing</b>
Yes	No	N/A	
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	As constructed accurately represents physical assets inspected and relevant items below are compliant with Code or Approved plan/variation. (6.1.1.3 Pr10255)
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Brass conduit markers indicate the position of the water service pipe crossing road pavement, are flush in centre face of kerb and within +/-150mm from actual water service conduit horizontal position. (SEQ-WAT-1108-1)
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Brass markers indicate the location of all water main crossing of road pavements and constructed concrete driveways and are flush in centre face of kerb. (SEQ-WAT-1300-1)

Unitywater  
 Office Use  
 Compliant:    Yes                       No

Compliant			<b>Table 6 – Water Reticulation - Flush Points</b>
Yes	No	N/A	
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	As constructed accurately represents physical assets inspected and relevant items below are compliant with Code or Approved plan/variation. (6.1.1.3 PR10255)
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Flush point boxes installed as per 5.10.4 WSA03 and associated drawings and is level with the FSL and pose no risk as a trip hazard.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Stainless steel ball valve. (SEQ-WAT-1104-1 Note 13)
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Stainless steel Storz fitting installed. (SEQ-WAT-1104-1)
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Stainless steel dust cap installed. (SEQ-WAT-1104-1)
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Detectable tape should be laid on top of the pipe embedment to form a continuous connection between valves and/or hydrants. Tape is to be accessible within flush point pit. (4.16 WSA03)
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Flush point box lid is painted correct colour as per colour code table on SEQ-WAT-1300-1
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Flush point brass kerb marker is flush in face of kerb and painted as per SEQ-WAT-1300-1 or marked with marker post as per SEQ-WAT-1300-2 if there is no kerb.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Thermoplastic reflective directional arrow installed (White).
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Pavement marker installed (All paint is compliant with SEQ code - sprayed not brushed, 2 coats of paint and glass bead - 100mm offset from centre line and correct height). (SEQ-WAT-1300-1)
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Pavement marker, kerb marker and brass marker (or marker post where applicable) are all in line with flush point box lid. (SEQ-WAT-1300-1)

Unitywater Office Use Compliant:	Yes <input type="checkbox"/>	No <input type="checkbox"/>
--	------------------------------	-----------------------------

Compliant			<b>Table 7 – Water Meters</b>
Yes	No	N/A	
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	As constructed accurately represents physical assets inspected and relevant items below are compliant with Code or Approved plan/variation. (6.1.1.3 Pr10255)
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Water meter poly pipe tail extends 600mm minimum outside water meter box into the lot it will service. (SEQ-WAT-1108-3)
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Water meter tail pipes are PE100 PN16 Black Pipe with blue stripe. (SEQ-WAT-1108-3)
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Water services are not turned off at the main (pressurised water main and release of sufficient water through the water meter tail). (Can be confirmed prior to inspection with individual photos verified by Construction Certifier that each ball valve is turned on) (SEQ-WAT-1108-3)
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Water meter and water meter box manufacturer complies with SEQ code (IPAM list approved).
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Factory preassembled water meter and water meter box manufacturer complies with SEQ Code (IPAM list approved) and is not modified.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Water meter box lid is correct colour (Black or Green), has non-slip pattern and "water meter" lettering cast into it. (SEQ-WAT-1108-3 Note 13)
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Water meter boxes and lids are not altered, damaged or modified (meter box sidewall deformation shall not exceed 5mm on any one side).
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Water meter box lid is attached via a chain/wire.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Water meter box is installed in correct location and configuration in accordance with SEQ-WAT-1108-2
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Water meter boxes located in constructed driveways or trafficable area are installed with approved trafficable lid.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Water meter boxes are correctly surrounded by turf 600mm on all sides (SEQ-WAT-1108-3 Note 15)
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Water meter box is flush with surrounding turf and the water meter box and surrounding turf is level with surrounding area and has no significant localised low or high points at the meter box location. (SEQ-WAT-1108-3 Note 14)
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Detectable marking tape installed and accessible inside meter box. Tape should also be laid on top of the pipe embedment from the main to the meter. (SEQ-WAT-1108-2 Note 8).
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	All connectors to water service pipes are approved fittings (brass or plastic - with manufacturer name and watermark to confirm compliance). (SEQ-WAT-1108-3 Note 9)
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Unitywater approved meter serial numbers that are stamped on meters and meter register record details are correct (6.1.1 Pr10255)
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Water meter ball valve is lockable, unobstructed within water meter box and manufacturer complies with SEQ code (IPAM list approved). (SEQ-WAT-1108-3)
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Geotextile fabric is installed around and underneath meter box and taped each side and around the service pipe (preventing ingress of sand, dirt and mud to water meter box). (SEQ-WAT-1108-3 Note 16)
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Water meter and inside of water meter box is clean (void of all sand, soil, mud and water).
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Water meter is installed facing straight up and not strapped/tied to water meter box.

Compliant			<b>Table 7 – Water Meters - Continued</b>	
Yes	No	N/A		
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Water meter and all components within water meter box are sitting high, level and centred within the box (minimum 20mm air gap between underside of the water meter and bottom of water meter box).	
			Unitywater Office Use Compliant:    Yes <input type="checkbox"/> No <input type="checkbox"/>	

Compliant			<b>Table 8 – Sewerage - Maintenance Structures - MH (Cast Insitu &amp; Pre-Cast)</b>	
Yes	No	N/A		
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	As constructed accurately represents physical assets inspected and relevant items below are compliant with Code or Approved plan/variation. (6.1.1.3 Pr10255)	
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	MH location is as per approved design/variation. (Section 22 WSA02)	
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Maintenance hole bench, channel and walls are clean and clear of silt, mud and water. (21.1 WSA02)	
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Inside finish of joints are not cement bagged over or mega-epoxy covered (Pre-cast or Cast Insitu MHs).	
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	No ladders or step irons are installed. (7.6.9 WSA02)	
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	No leaks/water ingress at joints including at converter slab join. (21.1 WSA02)	
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2 x S.S. brackets must be installed with maximum 1.5m spacing for internal backdrops deeper than 1.5m. (SEQ-SEW-1301-8, 1303-1&4)	
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	MH neck depth does not exceed 500mm maximum (no relaxation). (SEQ-SEW-1307-1 Section A-A)	
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Backdrop penetration is not within 150mm of joints in MH wall. (SEQ-SEW-1307-1 Section A-A)	
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Backdrop discharge is pointed downstream. (7.6.6 WSA02)	
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Backdrop tee has been installed in accordance with SEQ Code (to allow rodding of main).	
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Finished level of cover and surround to be flush with FSL and pose no risk as a trip hazard when located in roadway or 20mm above FSL when located in private property or footpath. (SEQ-SEW-1301-1)	
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Channel depth is SEQ Code compliant. (SEQ-SEW-1305-1)	
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Channel shape is SEQ Code compliant. (SEQ-SEW-1305-1)	
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Channel is not holding water (no ponding).	
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Benching is sloped at 1:8.	
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Smooth transitions exist between pipe and benched channel. (SEQ-SEW-1101-4 Note MH6)	
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	MH access opening is installed directly over downstream pipe outlet. (7.9.1 WSA02)	
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	PE lined MHs at required location and PE lining is correctly installed (mechanically anchored to wall - no lumps etc, lining in MH neck is welded to converter slab liner. Lining at MH access frame is installed correctly under cover and frame and welded to MH neck liner, collar welded into wall at backdrop - no mega epoxy to be used on lined MH. (17.2.6 WSA02)	
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Ensure cover frame opening aligns with converter slab opening.	
			Unitywater Office Use Compliant:    Yes <input type="checkbox"/> No <input type="checkbox"/>	

Compliant			<b>Table 9 – Sewerage - Maintenance Structures - MS</b>	
Yes	No	N/A		
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	As constructed accurately represents physical assets inspected and relevant items below are compliant with Code or Approved plan/variation. (6.1.1.3 Pr10255)	
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	MS location is as per approved design/variation. (Section 22 WSA02)	
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Maintenance shafts are clean and clean of silt, mud, water. (21.1 WSA02)	
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	MS manufacturer is approved (SEQ code IPAM List).	
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	MS risers are minimum 300mm in diameter. (7.7.2 WSA02)	
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	MS shrouds are 450mm diameter (375mm for terminal entry points). (SEQ-SEW-1314 & 1315 series)	
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	5/7mm washed screens installed around MS riser.	
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	MS risers are installed vertically.	
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	MS depths do not exceed 3.0m. (WSA02 Section 7.7.2)	
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Riser caps are a PVC bayonet cap with RRJ seal and a PVC RRJ socket (SEQ-SEW-1308-1 End of Note 8)	
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Inlets into riser are as per design/variation and SEQ Code. (Section 22 WSA02 & SEQ-SEW-1314-1)	
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Finished level of riser caps is 100mm minimum to 250mm maximum below bottom of cast iron lids. (SEQ-SEW-1308-1)	
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Finished level of MS cast iron lid to be Flush with FSL and pose no risk as a trip hazard when located in roadway or 20mm above FSL where located in private property or footpath. (SEQ-SEW-1303-1)	

Compliant			<b>Table 9 – Sewerage - Maintenance Structures - MS - Continued</b>
Yes	No	N/A	
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Lock down quick release end caps are SWJ fixed to riser and are rubber ring sealed between the cap and its frame (Screw down caps not allowed on MS Risers - Except terminal ends). (SEQ-SEW-1308-1 Note 8)
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	PVC caps open with less than 15-degree turn. (SEQ-SEW-1308-1 Note 8)
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	PVC caps are installed in the locked position.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Cover and surround manufacturer is approved (SEQ code IPAM List)
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Surround installed as per SEQ code and manufacturers requirements. (SEQ-SEW-1308-1)
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Marker tape should be laid on top of the pipe embedment to form a continuous connection between access cover frames. Tape are to be accessible in maintenance shaft shroud.
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Trafficable (Class D) and non-trafficable (Class B) cast iron covers installed in corresponding trafficable or non-trafficable locations. (SEQ-SEW-1308 series)

Unitywater  
 Office Use  
 Compliant:      Yes                       No

Compliant			<b>Table 10 - Sewer House Connections</b>
Yes	No	N/A	
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	As constructed accurately represents physical assets inspected and relevant items below are compliant with Code or Approved plan/variation. (6.1.1.3 Pr10255)
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Unitywater sewer property connections are marked with a 2.0-meter-long, single length, 40mm diameter orange PVC conduit at the sewer property connection upstream IL (check for dummy/broken markers). (SEQ-SEW-1106 series)
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Sewer property connection locations are as per approved plan/variation and SEQ Code. (Section 22 WSA02)
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Sewerage property connections have not been extended past what has been approved in the design/variation or SEQ Code.

Unitywater  
 Office Use  
 Compliant:      Yes                       No