

ANNUAL RECYCLED WATER PERFORMANCE REPORT

July 2015 - June 2016



Unitywater

Serving you today,
investing in tomorrow.

Contents

Introduction	3
Classes of Recycled Water	4
Recycled Water Scheme General Information	5
Units Of Measurement Definitions	6
Brendale Sewage Treatment Plant	7
Coolum Sewage Treatment Plant.....	8
Kawana Sewage Treatment Plant.....	9
Landsborough Sewage Treatment Plant.....	10
Maleny Sewage Treatment Plant	11
Maroochydore Sewage Treatment Plant.....	12
Murrumba Downs Sewage Treatment Plant	13
Nambour Sewage Treatment Plant	14
Noosa Sewage Treatment Plant.....	15
Redcliffe Sewage Treatment Plant.....	16
Woodford Sewage Treatment Plant.....	17
South Caboolture recycled water network	18

Introduction

Recycled water is supplied for customer reuse throughout the Unitywater supply region. Customers may use recycled water for a number of approved residential, commercial, municipal and industrial purposes.

Unitywater monitors the water quality of each recycled water scheme. This performance summary of monitoring results is provided to assist our customers to manage their onsite activities.

If you have any further questions regarding recycled water, please visit www.unitywater.com/Recycled-Water

12

SCHEMES SUPPLYING RECYCLED WATER

96

KM OF RECYCLED WATER MAINS

A+, A, B, C, D

CLASSES SUPPLIED

29

FIXED SITE COMMERCIAL, INDUSTRIAL AND MUNICIPAL CUSTOMERS

158

TANKER CARRIER CUSTOMERS

1,006

RESIDENTIAL CUSTOMERS

Approved uses of recycled water

Unitywater supplies five classes of recycled water: Class A+, Class A, Class B, Class C and Class D.

Each class is of a different quality and is restricted to certain uses.

Below is a summary list of approved uses by classification.

For further information on approved uses, please visit www.unitywater.com/Recycled-Water

Use	Class A+	Class A	Class B	Class C	Class D
Irrigation of residential gardens and lawns - above ground	✓	✗	✗	✗	✗
Irrigation of residential gardens and lawns - below ground	✓	✓	✗	✗	✗
Filling or topping up of residential 'non-drinking water' rainwater tanks is NOT PERMITTED	✗	✗	✗	✗	✗
Dust suppression, compaction	✓	✓	✓ ^a	✗	✗
Watering parks, playing fields, footpaths and roadside plants	✓	✓	✓ ^a	✓ ^a	✗
Filling fenced ponds, lagoons and dams (not used for recreational purposes)	✓	✓	✗	✗	✗
Filling non-fenced ponds, lagoons and dams (not used for recreational purposes)	✓	✗	✗	✗	✗
Road works	✓	✓	✓ ^a	✗	✗
Washing cars	✓	✗	✗	✗	✗
Washing animals (except pigs)	✓	✗	✗	✗	✗
Hydraulic testing of sewer infrastructure	✓	✓	✓	✓	✗
Irrigation of landscaping on construction sites	✓	✓	✓ ^a	✗	✗
Filling or topping up of swimming pools or spas NOT ALLOWED	✗	✗	✗	✗	✗
Irrigating sugar cane destined for non-edible purposes (fixed site users only)	✓	✓	✓	✓ ^a	✓ ^a
Irrigating turf (fixed site users only)	✓	✓	✓	✓ ^a	✓ ^a

✓ listed use is approved for this class of recycled water

✗ listed use not approved for this class of recycled water

^a use is accepted only under strict site controls including site management plans

Recycled water scheme general information

Scheme	Class Available Fixed-Site Customers	Class Available Tanker Fill Station	Tanker Fill Station Location
Brendale	Class B	Class B	3/26 Cribb Road
Coolum	Class B	Class B	Lot 2 Marsh Road
Kawana	Class B	Class B	Lot 101 Main Drive
Landsborough	Not supplied	Class B	Lot 10 Forestry Road
Maleny	Class B	Not supplied	Not supplied
Maroochydore	Class B / Class D	Class B	38 Commercial Road
Murrumba Downs	Class B	Class B	Lot 2 Bickle Road
Nambour	Class B / Class D	Class B	Lot 1 Bli Bli Road
Noosa	Class A	Class A	Lot 14 Wallum Lane
Redcliffe	Class C	Not supplied	Not Supplied
South Caboolture	Class A+	Class A+	<ul style="list-style-type: none"> ▪ 67 Weier Rd, Morayfield ▪ Mewett St, Caboolture ▪ Caboolture Regional Aquatic Centre Burpengary
Woodford	Class A	Class A	Neurum Road, adjacent Woodford Showgrounds

Definitions

Units/Parameter	Definition
MPN/100mL	Most Probable Number per 100 millilitre
CFU/mL	Colony Forming Units per millilitre
mg/L	milligrams per litre
µS/cm	Microsiemens per centimetre
pH units	pH units
NTU	Nephelometric Turbidity Units
Nitrogen (Ammonia)	Ammoniacal nitrogen (NH ₃ -N) is a measure for the amount of ammonia found in effluent.
Nitrogen (Oxidised)	The sum of nitrate-nitrogen (NO ₃ -N) and nitrite-nitrogen (NO ₂ -N) only
Nitrogen (total)	The sum of nitrate-nitrogen (NO ₃ -N), nitrite-nitrogen (NO ₂ -N), ammonia-nitrogen (NH ₃ -N) and organically bound nitrogen (N _{org} -N).
Phosphorous (total)	The sum of three forms of phosphorous species: reactive, condensed and organic.
Median	The middle value of the dataset. <i>E. coli</i> results are reported as a median in this performance report.

Brendale STP

Irrigator & tanker customers - Class B

Parameter	Units	Number of tests	Average
<i>E. coli</i>	MPN/100mL	53 ^b	<1*
Conductivity	µS/cm	51	696
Nitrogen (Ammonia)	mg/L	51	0.9
Nitrogen (Oxidised)	mg/L	51	1.7
Nitrogen (Total)	mg/L	51	4
pH	pH Units	52	7.3
Phosphorous (Total)	mg/L	51	0.95
Suspended Solids	mg/L	52	5

^b As per *Public Health Regulation 2005*, *E. coli* is sampled weekly, unless the recycled water scheme is isolated (e.g. due to planned maintenance)

*Median Value

Coolum STP

Irrigator & tanker customers - Class B

Parameter	Units	Number of tests	Average
E. coli	MPN/100mL	42 ^b	<1*
Conductivity	µS/cm	42	804
Nitrogen (Ammonia)	mg/L	42	0.4
Nitrogen (Oxidised)	mg/L	42	3.2
Nitrogen (Total)	mg/L	42	4.3
pH	pH Units	42	7.5
Phosphorous (Total)	mg/L	41	1
Suspended Solids	mg/L	42	3

^b As per *Public Health Regulation 2005*, *E. coli* is sampled weekly, unless the recycled water scheme is isolated (e.g. due to planned maintenance)

*Median Value

Kawana STP

Irrigator and industrial users
- Class B

Tanker customers -
Class B

Parameter	Units	Number of tests	Average	Number of tests	Average
E. coli	MPN/100mL	51 ^b	3*	51 ^b	<1*
Conductivity	µS/cm	52	1068	50	1066
Nitrogen (Ammonia)	mg/L	52	4.3	50	4
Nitrogen (Oxidised)	mg/L	52	2.3	50	3.9
Nitrogen (Total)	mg/L	52	8	50	9.4
pH	pH units	52	7.1	50	7.1
Phosphorous (Total)	pH units	52	4.1	52	4.1
Suspended Solids	mg/L	52	4	Not Tested	Not Tested

^b As per *Public Health Regulation 2005*, *E. coli* is sampled weekly, unless the recycled water scheme is isolated (e.g. due to planned maintenance)

*Median Value

Not Tested = parameter is not tested at this sample site

Landsborough STP

Tanker customers - Class B

Parameter	Units	Number of tests	Average
<i>E. coli</i>	MPN/100mL	49 ^b	1*
Conductivity	µS/cm	50	573
Nitrogen (Ammonia)	mg/L	50	0.7
Nitrogen (Oxidised)	mg/L	50	1.4
Nitrogen (Total)	mg/L	50	3.2
pH	pH Units	50	7.5
Phosphorous (Total)	mg/L	50	1.6
Suspended Solids	mg/L	50	4

^b As per *Public Health Regulation 2005*, *E. coli* is sampled weekly, unless the recycled water scheme is isolated (e.g. due to planned maintenance)

*Median Value

Maleny STP

Irrigator customers - Class B

Parameter	Units	Number of tests	Average
<i>E. coli</i>	MPN/100mL	52 ^b	<1*
Conductivity	µS/cm	53	497
Nitrogen (Ammonia)	mg/L	53	<0.05
Nitrogen (Oxidised)	mg/L	53	1.5
Nitrogen (Total)	mg/L	53	2
pH	pH Units	53	7.1
Phosphorous (Total)	mg/L	53	0.6
Suspended Solids	mg/L	53	3

^b As per *Public Health Regulation 2005*, *E. coli* is sampled weekly, unless the recycled water scheme is isolated (e.g. due to planned maintenance)

*Median Value

Maroochydore STP

Cane Irrigator - Class B

Irrigator & tanker customers - Class B

Parameter	Units	Number of tests	Average	Number of tests	Average
<i>E. coli</i>	MPN/100mL	54 ^b	305*	53 ^b	<1*
Conductivity	µS/cm	53	1948	53	1948
Nitrogen (Ammonia)	mg/L	53	0.5	53	0.5
Nitrogen (Oxidised)	mg/L	53	3	53	3
Nitrogen (Total)	mg/L	53	4.3	53	4.3
pH	pH units	53	7	53	7
Phosphorous (Total)	mg/L	52	0.15	52	0.15
Suspended Solids	mg/L	53	5	53	5

^b As per *Public Health Regulation 2005*, *E. coli* is sampled weekly, unless the recycled water scheme is isolated (e.g. due to planned maintenance)

*Median Value

Murrumba Downs STP

Irrigator & tanker customers - Class B

Parameter	Units	Number of tests	Average
<i>E. coli</i>	MPN/100mL	54 ^b	<1*
Conductivity	µS/cm	52	711
Nitrogen (Ammonia)	mg/L	52	0.1
Nitrogen (Oxidised)	mg/L	52	<0.5
Nitrogen (Total)	mg/L	52	1
pH	pH Units	52	7.8
Phosphorous (Total)	mg/L	52	1
Suspended Solids	mg/L	53	<2

^b As per Public Health Regulation 2005, *E. coli* is sampled weekly, unless the recycled water scheme is isolated (e.g. due to planned maintenance)

*Median Value

Nambour STP

Irrigator & tanker customers
- Class B

Turf irrigator
customers - Class D

Parameter	Units	Number of tests	Average	Number of tests	Average
E. coli	MPN/100mL	51 ^b	<1*	53 ^b	50*
Conductivity	µS/cm	53	842	53	842
Nitrogen (Ammonia)	mg/L	53	0.5	53	0.5
Nitrogen (Oxidised)	mg/L	53	0.6	53	0.6
Nitrogen (Total)	mg/L	53	2.2	53	2.2
pH	pH units	53	7.5	53	7.5
Phosphorous (Total)	mg/L	52	7.5	52	7.5
Suspended Solids	mg/L	53	3	53	3

^b As per *Public Health Regulation 2005*, *E. coli* is sampled weekly, unless the recycled water scheme is isolated (e.g. due to planned maintenance)

*Median Value

Noosa STP

Irrigator & tanker customers - Class A

Parameter	Units	Number of tests	Average
<i>E. coli</i>	MPN/100mL	49 ^b	1*
Conductivity	µS/cm	42	1434
Nitrogen (Ammonia)	mg/L	50	0.1
Nitrogen (Oxidised)	mg/L	50	2.7
Nitrogen (Total)	mg/L	42	3.6
pH	pH Units	42	7.6
Phosphorous (Total)	mg/L	42	0.3
Suspended Solids	mg/L	42	3

^b As per Public Health Regulation 2005, *E. coli* is sampled weekly, unless the recycled water scheme is isolated (e.g. due to planned maintenance)

*Median Value

Redcliffe STP

Irrigator customers - Class C

Parameter	Units	Number of tests	Average
<i>E. coli</i>	MPN/100mL	49 ^b	1*
Conductivity	µS/cm	51	1544
Nitrogen (Ammonia)	mg/L	49	0.6
Nitrogen (Oxidised)	mg/L	49	1.3
Nitrogen (Total)	mg/L	49	3
pH	pH Units	51	7.1
Phosphorous (Total)	mg/L	49	0.2
Suspended Solids	mg/L	49	3

^b As per *Public Health Regulation 2005*, *E. coli* is sampled weekly, unless the recycled water scheme is isolated (e.g. due to planned maintenance)

*Median Value

Woodford STP

Irrigator & tanker customers - Class A

Parameter	Units	Number of tests	Average
<i>E. coli</i>	MPN/100mL	48 ^b	<1*
Conductivity	µS/cm	52	689
Nitrogen (Ammonia)	mg/L	49	0.1
Nitrogen (Oxidised)	mg/L	49	2.9
Nitrogen (Total)	mg/L	49	3.7
pH	pH Units	52	7.4
Phosphorous (Total)	mg/L	49	0.2
Suspended Solids	mg/L	50	<2

^b As per *Public Health Regulation 2005*, *E. coli* is sampled weekly, unless the recycled water scheme is isolated (e.g. due to planned maintenance)

*Median Value

South Caboolture recycled water network

Commercial, industrial, municipal & residential customers - Class A+

Parameter	Units	Number of tests	Average
<i>E. coli</i>	MPN/100mL	49 ^b	<1*
Free chlorine	mg/L	241	0.27
Total Chlorine	mg/L	241	1.33
Conductivity	µS/cm	240	202
Turbidity	NTU	246	0.2

^b As per *Public Health Regulation 2005*, *E. coli* is sampled weekly, unless the recycled water scheme is isolated (e.g. due to planned maintenance)

*Median Value



Unitywater

ABN: 89 791 717 472

Head Office

Ground Floor, 33 King Street, Caboolture, QLD

PO Box 953, Caboolture QLD 4510

T: 1300 0 UNITY (1300 086 489)

F: (07) 5431 8288

www.unitywater.com

Unitywater has certification to
OH&S ISO 4801
Environmental ISO 14001
Quality Systems ISO 9001
Food Safety Management ISO 22000



SCI QUAL
INTERNATIONAL



SCI QUAL
INTERNATIONAL



SCI QUAL
INTERNATIONAL



WORLD RECOGNISED
ACCREDITATION



FOOD
SAFETY
MANAGEMENT SYSTEM CERTIFIED TO
ISO 22000:2018
REGISTRATION NUMBER: 95000076 FOSM/2018

