



Annual Sewage Treatment Plant Performance Report

1 JULY 2021 – 30 JUNE 2022

Sewage Treatment Plants at a glance



311,514

Number of sewerage
assets connections

6,101 KM

Kilometres of sewer
main pipes

800

Number of sewage
pump stations

17

Number of sewage
treatment plants

73,784 ML¹

Volume of sewage
collected and treated

99.8%

of biosolids
reused

2050

sustainability target
Net zero carbon
emissions

97%

Quality and quantity
compliance

¹ Does not include 1070 ML diverted to Urban Utilities via the Kedron Brook Sewerage Scheme. This sewage would be treated to UU's licence requirements

Contents

Sewage Treatment Plants at a glance	2
Message from the CEO	6
1. Introduction	8
1.1 Quick Statistics July 2021 - June 2022	9
1.2 Rainfall	10
1.3 Mass Load Releases	11
2. Effluent Quality Summary	15
3. Performance in Detail (July 2021 – June 2022)	17
3.1 Brendale Sewage Treatment Plant	17
3.2 Bribie Island Sewage Treatment Plant	20
3.3 Burpengary East Sewage Treatment Plant	22
3.4 Coolum Sewage Treatment Plant	24
3.5 Cooroy Sewage Treatment Plant	27
3.6 Dayboro Sewage Treatment Plant	30
3.7 Kawana-Landsborough Sewage Treatment Plants	34
3.8 Kenilworth Sewage Treatment Plant	36
3.9 Maleny Sewage Treatment Plant	37
3.10 Maroochydore Sewage Treatment Plant	38
3.11 Murrumba Downs Sewage Treatment Plant	41
3.12 Nambour Sewage Treatment Plant	47
3.13 Noosa Sewage Treatment Plant	51
3.14 Redcliffe Sewage Treatment Plant	52
3.15 South Caboolture Sewage Treatment Plant	55
3.16 Woodford Sewage Treatment Plant	61
4. Definitions and Legend	65

List of Tables

Table 1	Effluent Compliance	15
Table 2	Compliance Range Legend	17
Table 3	Brendale STP Release Targets	17
Table 4	Brendale STP Mass Limits	17
Table 5	Bribie Island STP Contaminant Release Targets	20
Table 6	Burpengary East STP Release Targets	22
Table 7	Burpengary STP Mass Limits	22
Table 8	Coolum STP Release Targets	24
Table 9	Coolum STP Mass Limits	24
Table 10	Cooroy STP Release Targets	27
Table 11	Cooroy STP Mass Limits	27
Table 12	Dayboro STP Contaminants Release Targets	30
Table 13	Kawana-Landsborough STP Release Targets ^{1,3}	34
Table 14	Kenilworth STP Release Targets ¹	36
Table 15	Maleny STP Release Targets to Constructed Wetlands	37
Table 16	Maleny STP Release Targets to Forest Irrigation	37
Table 17	Maroochydore STP Release Targets	38
Table 18	Maroochydore STP Mass Limits	38
Table 19	Murrumba Downs STP Release Targets	41
Table 20	Murrumba Downs STP Volumetric Limits	42
Table 21	Murrumba Downs STP Mass Limits	42
Table 22	Nambour STP Release Targets	47
Table 23	Noosa STP Release Targets	51
Table 24	Noosa STP Mass Limits	51
Table 25	Redcliffe STP Release Targets	52
Table 26	Redcliffe STP Mass Limits	52
Table 27	South Caboolture STP Release Targets	55
Table 28	South Caboolture STP Mass Limits	55
Table 29	Woodford STP Release Targets	61
Table 30	Woodford STP Mass Limits	61
Table 31	Acronyms and Definitions	65
Table 32	Definition of Units	66

List of Figures

Figure 1	Southern Region Rainfall	10
Figure 2	Northern Region Rainfall	11
Figure 3	STP with Mass Licence – Total Nitrogen	12
Figure 4	STP with Mass Licence – Total Phosphorus	13
Figure 5	Brendale STP - TSS - Maximum	18
Figure 6	Brendale STP - Faecal Coliforms - Median	19
Figure 7	Brendale STP - Faecal Coliforms - 80th Percentile	19
Figure 8	Bribie Island STP – Total Phosphorus – Maximum	21
Figure 9	Burpengary East STP - Faecal Coliforms - Median	23
Figure 10	Coolum STP – DO – Minimum	25
Figure 11	Coolum STP – Ammonia – Maximum	26
Figure 12	Cooroy STP - Total Nitrogen - Maximum	28
Figure 13	Cooroy STP - Intestinal Enterococci - Maximum	29
Figure 14	Dayboro STP - Ammonia - 50th Percentile	31
Figure 15	Dayboro STP - Ammonia - Maximum	32
Figure 16	Dayboro STP - <i>E.Coli</i> - Median	33
Figure 17	Dayboro STP - <i>E.Coli</i> - 80th Percentile	33
Figure 18	Kawana STP - BOD - Long Term 80th Percentile	35
Figure 19	Maroochydore STP - Faecal Coliforms - Median	39
Figure 20	Maroochydore STP - Faecal Coliforms - 80th Percentile	40
Figure 21	Murrumba Downs STP - BOD - Short Term 80th Percentile	43
Figure 22	Murrumba Downs STP - Total Phosphorus - Maximum	44
Figure 23	Murrumba Downs STP - Faecal Coliforms - Median	45
Figure 24	Murrumba Downs STP - Faecal Coliforms - 80th Percentile	46
Figure 25	Nambour STP - Ammonia - Maximum	48
Figure 26	Nambour STP - Faecal Coliforms - Median	49
Figure 27	Nambour STP - Faecal Coliforms - 80th Percentile	50
Figure 28	Redcliffe STP - Faecal Coliforms - Median	53
Figure 29	Redcliffe STP - Faecal Coliforms - 80th Percentile	54
Figure 30	South Caboolture STP – BOD – Maximum	56
Figure 31	South Caboolture STP – TSS – Maximum	57
Figure 32	South Caboolture STP – TSS – Short Term 80th Percentile	58
Figure 33	South Caboolture STP – TSS – Long Term 80th Percentile	58
Figure 34	South Caboolture STP – pH – Minimum	59
Figure 35	South Caboolture STP – Faecal Coliforms – Median	60
Figure 36	South Caboolture STP – Faecal Coliforms – 80th Percentile	60
Figure 37	Woodford STP – BOD – Maximum	62
Figure 38	Woodford STP – TSS – Maximum	63

Message from the CEO

Dear Customers

This year was like no other for Unitywater's network of 17 Sewage Treatment Plants (STPs).

Our STPs were put to the test early in 2022 when an extreme weather event caused flooding and widespread damage throughout South East Queensland.

Despite the widespread impacts, our team's planned response kicked in to ensure we achieved 96.6% of our sewage treatment plant effluent compliance measures for the year as a clear demonstration of our resilience and ability to deliver sewerage services, day in and day out.

While part of our team weathered the storm, the other had our shared future in mind. We continued to plan for the projected growth of our region and sewerage network with two major plants approved for upgrades in the Moreton Bay region.

Brendale and Burpengary East STPs are set to undergo major upgrades that will increase capacity until 2051 and 2032 respectively. These upgrades will position our network for the additional capacity of emerging communities.

This year we continued to invest in sustainable projects that provide clever solutions to the reuse of wastewater. Nearly half of the 22km pipeline was laid as part of the Wamuran Irrigation Scheme that will carry 2.6GL (gigalitres) of Class A recycled water per year from our South Caboolture STP to the local agricultural community.

Wamuran Irrigation Scheme is one of the ways that our STPs will contribute to our pledge to reach net zero emissions by 2050. Upgrades to our STPs are also set to save the equivalent of \$2.5 million per annum in energy costs from 2020 to 2027, as well as reduce landfill from STPs to zero.





I am certain that the challenges and opportunities presented by our growing region and changing climate will continue. Based on our strong sewage treatment plant performance, I am confident the Unitywater team will continue to meet these changes into the future.


Chief Executive Officer

Anna Jackson

Our supply area

LEGEND

-  Corporate Centres
-  Service Centres
-  Sewage Treatment Plants
-  Sewage Rising Main



A large, white, sans-serif number '1' is centered on the left side of the page. The background consists of several overlapping circular shapes in various shades of blue, creating a modern, abstract design.

INTRODUCTION

1. Introduction

Unitywater supplies more than 830,000 people across 5,223 square kilometres with sewerage and water services.

We monitor effluent quality from each sewage treatment plant to assess compliance with conditions specified under the licence granted by the Department of Environment and Science (DES). We hold the following DES registration and approval:

- a. A single Registration Certificate, authorising Unitywater to operate sewage treatment plants; and
- b. A single Environmental Authority (Environmental Licence) for the following sewage treatment plants:

- Brendale
- Burpengary East
- Bribie Island
- Coolum
- Cooroy
- Dayboro
- Kawana
- Kenilworth
- Landsborough
- Maleny
- Maroochydore
- Murrumba Downs
- Nambour
- Noosa
- Redcliffe
- South Caboolture
- Suncoast (decommissioned)
- Woodford

Should we not meet our obligations as set out in the licence, penalties may apply in accordance with the *Sustainable Planning Act 2009* and *Environmental Protection Act 1994*. We report our compliance results each month to the Department of Environment and Science and provide detailed commentary as required to address specific items of note.

This report is published to provide information about effluent quality and some licence compliance statistics from our sewage treatment plants. By meeting licence conditions, we ensure high quality service, minimising impacts on waterways in our local communities.

1.1 Quick Statistics July 2021 - June 2022

KILOMETRES OF SEWER MAIN PIPES	6,101KM
NUMBER OF SEWAGE PUMP STATIONS	800
NUMBER OF SEWAGE TREATMENT PLANTS	17
VOLUME OF SEWAGE COLLECTED AND TREATED	73,784 ML¹

1. Does not include 1070 ML diverted to Urban Utilities via the Kedron Brook Sewerage Scheme. This sewage would be treated to UU's licence requirements.

1.2. Rainfall

Significant rainfall in the 2021-22 financial year, as shown graphically in Figure 1 and Figure 2, has been a major contributor to the reported non-compliances. For example, in the southern region, the rain received in the month of February 2022 was only 6mm less than of the total annual rainfall of 2019-20. Analysis presented in the *Special Climate Statement 67* from the Bureau of Meteorology stated, “The multi-day accumulation of intense rainfall resulted in many areas receiving more than half their average annual (over the 1961–1990 period) rainfall total in just a week.”¹

1. <http://www.bom.gov.au/climate/current/statements/scs76.pdf?20220525>

Figure 1 – Southern Region Rainfall





Figure 2 – Northern Region Rainfall



Intense or prolonged rainfall affects treatment plants in various ways. The primary effect is the reduction of hydraulic retention time, meaning water spends less time on site and therefore has less opportunity to be treated. Whilst treatment plants are designed to produce compliant effluent during these events, they are not over designed for such unprecedented rain events. Therefore during these events, equipment and processes are pushed to capacity.


1.3. Mass Load Releases

Graphs of mass loads (see Table 31 for definition) released from sites with load discharge limits to the environment are shown below for information purposes. All treatment plants are within their licenced mass load limits for the 2021–22 period.

The graphs show variability from year to year. Nitrogen and phosphorus mass discharge varies for several reasons, including:

- Annual rainfall (variability of mass load due to the effect of wet weather flows on treatment processes).
- Increasing plant raw sewage loads (as the community grows, influent nutrient mass load will gradually increase).
- Balancing nitrogen and phosphorus removal with the associated power and chemical consumption and their environmental impacts, through plant optimisation and improvement activities.
- The continuing decline in the community's use of phosphate containing detergents.


Figure 3 – STP with Mass Licence – Total Nitrogen



It is worth noting the changes in effluent quality due to Unitywater’s continued optimisation, renewal and upgrade activities. In relation to Total Nitrogen:

- Burpengary STP is approaching its design capacity and planning is currently underway for a plant upgrade due for completion in 2024.
- Maroochydore STP has experienced increasing sewage load due to population growth in the region. Unitywater has invested in improving the technology and reliability of the plant resulting in improved nutrient removal performance.
- Redcliffe STP has continued to undergo construction, renewal and refurbishment works, with various process units offline across the year, impacting the nutrient removal capabilities. The plant continues to operate compliant with its mass licence.

Figure 4 – STP with Mass Licence – Total Phosphorus



In relation to Total Phosphorus;

- Coolum STP is nearing its capacity limits and hence higher nutrient levels however within licence limits. Unitywater is currently in the planning phase of upgrading the biological nutrient reduction process.
- Murrumba Downs STP's phosphorus removal is primarily biologically based (not dependent on chemical usage) and is therefore affected by significant wet weather events, of which 2021-22 has had many, increasing the total effluent phosphorous mass.



2 EFFLUENT QUALITY SUMMARY

2. Effluent Quality Summary

DES requires that all sewage treatment plants discharge effluent that meets quality and quantity conditions to minimise impacts on the health of waterways in Queensland. Concentrations of contaminants such as organic matter, suspended solids, chlorine and pathogens are measured and reported. Release volumes and mass loads are also evaluated to compare with limits specified by DES.

In the 2021-22 financial year, Unitywater achieved 97% quality and quantity compliance for sewage discharged from its sewage treatment plants against overall effluent standards. DES allows fluctuations in effluent quality parameters (DEHP, 2014) and therefore all plants performed within the quality standards set by the Environmental Licence. The table below provides a summary of where treated effluent is discharged and overall effluent quality compliance in the 2021-22 financial year.

Table 1 – Effluent Compliance

Sewage Treatment Plant	Catchment Equivalent Population	Treatment Process	Discharge to:			Effluent and Flow Compliance
			Freshwater Body	Ocean	Irrigation, Wetlands or Groundwater	
Brendale	40,717	BNR ¹	✓			99%
Bribie Island	31,451	Biological nitrogen removal and chemical phosphorus removal			✓	98%
Burpengary East	65,546	BNR	✓			100%
Coolum	31,106	BNR	✓			100%
Cooroy	5,072	BNR	✓		✓	99%
Dayboro	1,053	Biological nitrogen removal			✓	94%
Kawana	150,722	Biological nitrogen removal	✓	✓		91% ³
Kenilworth	372	Oxidation Pond	✓		✓	100%
Landsborough ²	11,805	BNR	✓	✓		100%
Maleny	2,684	Biological nitrogen removal and chemical phosphorus removal	✓		✓	100%
Maroochydore	86,459	BNR	✓			96%
Murrumba Downs	147,003	BNR	✓			98%
Nambour	49,102	BNR	✓			96%
Noosa	48,792	BNR	✓			100%
Redcliffe	65,377	BNR		✓		100%
South Caboolture	73,067	BNR	✓			97%
Woodford	3,264	Biological nitrogen removal and chemical phosphorus removal	✓			100%
	Overall Compliance (flow weighted)					97%

- Notes:
1. Biological Nutrient Reduction (BNR) – Reduces nitrogen and phosphorus biologically.
 2. A separate 'Performance in Detail' table is not provided for Landsborough Sewage Treatment Plant as effluent from this facility is combined with Kawana Sewage Treatment Plant effluent before being released to the outfall.
 3. Percent compliance reduction due to discharge flow limits exceedances. Effluent quality continues to meet licence requirements. A licence amendment is in progress.

The background consists of several overlapping circles in two shades of blue: a darker navy blue and a lighter sky blue. A large, white, stylized number '3' is positioned on the left side, partially overlapping the circles. To the right of the '3', the text 'PERFORMANCE IN DETAIL' is written in a white, sans-serif font, stacked in two lines.

3

PERFORMANCE
IN DETAIL

3. Performance in Detail

JULY 2021 – JUNE 2022

Note that the release parameters differ from plant to plant (e.g. Brendale STP has mass load limits while Bribe Island STP does not). This is often due to the nature of the discharge point (e.g. waterway or land) or when the plant was issued DES approval to operate. Indication of level of compliance is provided as per Table 2 below.

Table 2 – Compliance Range Legend

Symbol	Compliance Range
✓	> 90%
✓	80% - 90%
✗	< 80%

3.1 Brendale Sewage Treatment Plant

Table 3 - Brendale STP Release Targets

Parameter	Unit	Number of Samples	Target Type	Compliant
BOD	mg/L	52	long term 80th percentile	✓
			short term 80th percentile	✓
			maximum	✓
TSS	mg/L	52	long term 80th percentile	✓
			short term 80th percentile	✓
			maximum	✓ ¹
pH	pH units	52	range	✓
DO	mg/L	52	minimum	✓
Free Chlorine Residual	mg/L	52	maximum	✓
Faecal Coliforms	cfu/100 mL	260	median	✓ ²
			80th percentile	✓ ²

1. TSS Maximum was exceeded one time in the 2021-22 financial year. Please refer to the next page for further details.
2. Faecal Coliforms Median was exceeded four times and the 80th Percentile was exceeded one time. Please refer to the next page for further details.

Table 4 – Brendale STP Mass Limits

Parameter	Unit	Number of Days	Limit Type	Compliant
Average Annual Flow	ML/yr	365	maximum	✓
Nitrogen Mass Load	kg/yr	-	maximum	✓
Phosphorus Mass Load	kg/yr	-	maximum	✓

3.2 Bribie Island Sewage Treatment Plant

Table 5 – Bribie Island STP Contaminant Release Targets

Parameter	Unit	Number of Samples	Target Type	Compliant
BOD	mg/L	52	long term 80th percentile	✓
			short term 80th percentile	✓
			maximum	✓
TSS	mg/L	52	long term 80th percentile	✓
			short term 80th percentile	✓
			maximum	✓
pH	pH units	52	range	✓
DO	mg/L	52	minimum	✓
TN	mg/L	52	long term 50th percentile	✓
			short term 50th percentile	✓
			maximum	✓
TP	mg/L	52	long term 50th percentile	✓
			short term 50th percentile	✓
			maximum	✓ ¹


1. Total Phosphorus Maximum was exceeded one time in the 2021-22 financial year. Please refer to the next page for further details

Exceedances

TOTAL PHOSPHORUS

Total Phosphorus Maximum was outside the required range once.. A pump failure caused a total phosphorus exceedance. The pump was immediately fixed. Overall 98% compliance in Total Phosphorus targets was achieved in the 2021-22 financial year.

Figure 8 – Bribie Island STP – Total Phosphorus – Maximum



3.3 Burpengary East Sewage Treatment Plant

Table 6 – Burpengary East STP Release Targets

Parameter	Unit	Number of Samples	Target Type	Compliant
BOD	mg/L	52	long term 80th percentile	✓
			short term 80th percentile	✓
			maximum	✓
TSS	mg/L	52	long term 80th percentile	✓
			short term 80th percentile	✓
			maximum	✓
pH	pH units	52	range	✓
DO	mg/L	52	minimum	✓
Free Chlorine Residual	mg/L	52	maximum	✓
Faecal Coliforms	cfu/100 mL	260	median	✓ ¹
			80th percentile	✓

1. Faecal Coliforms median was exceeded one time in the 2021-22 financial year. Please refer to the next page for further details.


Table 7 – Burpengary STP Mass Limits

Parameter	Unit	Number of Days	Limit Type	Compliant
Average Annual Flow	ML/yr	365	maximum	✓
Nitrogen Mass Load	kg/yr	-	maximum	✓
Phosphorus Mass Load	kg/yr	-	maximum	✓

FAECAL COLIFORMS

Target Median Faecal Coliforms was exceeded once. This Faecal Coliform exceedance was due to high flows associated with 824mm of rainfall received in three days. 98% compliance with the Faecal Coliforms median was achieved in the 2021-22 financial year.

Figure 9 – Burpengary East STP – Faecal Coliforms – Median



3.4 Coolum Sewage Treatment Plant

Table 8 – Coolum STP Release Targets

Parameter	Unit	Number of Samples	Target Type	Compliant
BOD	mg/L	52	long term 80th percentile	✓
			short term 80th percentile	✓
			maximum	✓
TSS	mg/L	52	long term 80th percentile	✓
			short term 80th percentile	✓
			maximum	✓
pH	pH units	52	range	✓
DO	mg/L	52	minimum	✓ ¹
NH ₃ -N	mg/L	52	long term 50th percentile	✓
			maximum	✓ ²
Free Chlorine Residual	mg/L	52	maximum	✓
Faecal Coliforms	cfu/100 mL	52	median	✓
			80th percentile	✓

1. Dissolved Oxygen Minimum was exceeded once in the 2021-22 financial year. Please refer to the next page for further details.
2. Ammonia maximum was exceeded once in the 2021-22 financial year. Please refer to the next page for further details.

Table 9 – Coolum STP Mass Limits


Parameter	Unit	Number of Days	Limit Type	Compliant
Average Annual Flow	ML/yr	365	maximum	✓
Nitrogen Mass Load	kg/yr	-	maximum	✓
Phosphorus Mass Load	kg/yr	-	maximum	✓

Exceedances

DISSOLVED OXYGEN

Dissolved Oxygen Minimum was exceeded once following 205mm of rain. Overall 98% compliance with the Dissolved Oxygen Minimum limit was achieved in the 2021-22 financial year.

Figure 10 – Coolum STP – DO – Minimum



3.5 Cooroy Sewage Treatment Plant

Table 10 – Cooroy STP Release Targets

Parameter	Unit	Number of Samples	Target Type	Compliant
TSS	mg/L	52	long term 80th percentile	✓
			short term 80th percentile	✓
			maximum	✓
pH	pH units	52	range	✓
DO	mg/L	52	minimum	✓
TN	mg/L	52	long term 50th percentile	✓
			maximum	✓ ¹
TP	mg/L	52	long term 50th percentile	✓
			maximum	✓
Intestinal Enterococci	mg/L	52	long term 50th percentile	✓
			maximum	✓ ²

1. Total Nitrogen maximum was exceeded once in the 2021-22 financial year. Please refer to the next page for further details.
2. Intestinal Enterococci Maximum was exceeded twice in the 2021-22 financial year. Please refer to the next page for further details.

Table 11 – Cooroy STP Mass Limits


Parameter	Unit	Limit Type	Compliant
Nitrogen Mass Load	kg/yr	maximum	✓
Phosphorus Mass Load	kg/yr	maximum	✓

Exceedances

TOTAL NITROGEN

Total Nitrogen Maximum was exceeded once following a dissolved oxygen probe fault. Nitrogen levels promptly reduced to compliance levels following repairs to the probe. Overall 98% compliance with the Total Nitrogen Maximum limit was achieved in the 2021-22 financial year.

Figure 12 – Cooroy STP – Total Nitrogen – Maximum



3.6 Dayboro Sewage Treatment Plant

Table 12 – Dayboro STP Contaminants Release Targets

Parameter	Unit	Number of Samples	Target Type	Compliant
BOD	mg/L	12	80th percentile	✓
			maximum	✓
TSS	mg/L	12	80th percentile	✓
			maximum	✓
pH	pH units	12	range	✓
NH ₃ -N	mg/L	12	50th percentile	✗ ¹
			maximum	✓ ¹
<i>E. coli</i>	mg/L	60	median	✓ ²
			80th percentile	✓ ²

1. 50th Percentile Ammonia was exceeded five times and Maximum Ammonia was exceeded twice in the 2021-22 financial year. Please refer to the next page for further details.
2. Median *E. coli* was exceeded two times and 80th Percentile *E. coli* was exceeded once in the 2021-22 financial year. Please refer to the next page for further details.

Exceedances

AMMONIA

50th Percentile Ammonia was exceeded five times and Maximum Ammonia was exceeded twice. Each exceedance was related to rainfall affecting plant performance. Overall 83% compliance with the Ammonia Maximum and 58% compliance with the Ammonia 50th Percentile limit was achieved in the 2021-22 financial year. There is no risk to the environment nor the community as effluent is diluted in a large effluent storage dam and then disposed of via on-site land irrigation.

Figure 14 – Dayboro STP – Ammonia – 50th Percentile





Figure 15 – Dayboro STP – Ammonia – Maximum



E. COLI

Target Median *E. coli* was exceeded twice and 80th Percentile *E. coli* was exceeded once. The December and March exceedances were associated with rainfall events of 172mm over 3 days and 866mm of rain respectively. 83% compliance with the *E. coli* median was achieved, improving on the 2020-21 result of 77%. 92% compliance with *E. coli* 80th Percentile limits were achieved in the 2021-22 financial year, improving on the 2020-21 result of 77%. There is no risk to the environment nor the community due to reduced disinfection performance as effluent is disposed of via on-site land irrigation.

Figure 16 – Dayboro STP – E. coli – Median





Figure 17 – Dayboro STP – E. coli – 80th Percentile



3.7 Kawana-Landsborough Sewage Treatment Plants

Table 13 – Kawana-Landsborough STP Release Targets^{1,3}


Parameter	Unit	Number of Samples	Target Type	Compliant
BOD	mg/L	52	long term 80th percentile	✘ ²
			maximum	✓
TSS	mg/L	52	long term 80th percentile	✓
			maximum	✓
pH	pH units	52	range	✓
DO	mg/L	52	minimum	✓
NH ₃ -N	mg/L	52	long term 50th percentile	✓
			maximum	✓
Free Chlorine Residual	mg/L	52	maximum	✓
Faecal Coliforms	cfu/100 mL	52	median	✓
			80th percentile	✓

1. Note that effluent to the main outfall contains flow from both Kawana and Landsborough Sewage Treatment Plants.
2. BOD Long term 80th Percentile was exceeded 15 times in the 2021-22 financial year. Please refer to the next page for further details.
3. The dry weather flow limit in the Environmental Authority has been exceeded and reported. This is due to diverting flows from Maroochydore STP to Kawana STP in advance of undertaking important renewal work at Maroochydore STP. Unitywater is currently investigating the future capacity requirements of the plant to meet the local community's significant growth. With this information, Unitywater will apply for an amendment to the Environmental Authority.

BOD

BOD short term 80th Percentile was exceeded 15 times due to commissioning of the newly upgraded plant and due to the extreme rainfall received this year. Post-commissioning the plant is meeting its BOD requirements. 71% compliance was attained for Long term 80th Percentile BOD in the 2021-22 financial year.

Figure 18 – Kawana STP – BOD – Long Term 80th Percentile



3.8 Kenilworth Sewage Treatment Plant

Table 14 – Kenilworth STP Release Targets¹

Parameter	Unit	Number of Samples	Target Type	Compliant
BOD	mg/L	52	long term 80th percentile	✓
			short term 80th percentile	✓
			maximum	✓
TSS	mg/L	52	long term 80th percentile	✓
			short term 80th percentile	✓
			maximum	✓
pH	pH units	52	range	✓
DO	mg/L	52	minimum	✓
Conductivity	µs/cm	52	long term 50th percentile	✓
			maximum	✓
Faecal Coliforms	cfu/100 mL	52	median	✓
			80th percentile	✓

1. Note that Kenilworth Sewage Treatment Plant releases treated effluent to land disposal with no discharge to waterways. Discharge to waters limits are not assessed and therefore 100% compliance was attained.

3.9 Maleny Sewage Treatment Plant

Table 15 – Maleny STP Release Targets to Constructed Wetlands

Parameter	Unit	Number of Samples ^	Target Type	Compliant
TSS	mg/L	52	long term 80th percentile	✓
			short term 80th percentile	✓
pH	pH units	52	range	✓
DO	mg/L	52	minimum	✓
TN	mg/L	52	long term 50th percentile	✓
TP	mg/L	52	long term 50th percentile	✓
<i>E. coli</i>	cfu/100mL	52	median	✓

Table 16 – Maleny STP Release Targets to Forest Irrigation

Parameter	Unit	Number of Samples ^	Limit Type	Compliant
pH	pH units	52	range	✓
Electrical Conductivity	µs/cm	52	maximum	✓
TN	mg/L	52	maximum	✓
TP	mg/L	52	maximum	✓
<i>E. coli</i>	cfu/100 mL	52	median	✓

1. Total number of samples of effluent. Note that effluent released to the constructed wetlands and forest irrigation is sampled from the same location. Flow is diverted to either outfall on any one day, however not both outfalls.

3.10 Maroochydore Sewage Treatment Plant

Table 17 – Maroochydore STP Release Targets

Parameter	Unit	Number of Samples	Target Type	Compliant
Faecal Coliforms	cfu/100 mL	52	median	✓ ¹
			80th percentile	✓ ¹

1. 1. Faecal Coliforms Median was exceeded two times and 80th percentile was exceeded eight times in the 2021-22 financial year. Please refer to the next page for further details.

Table 18 – Maroochydore STP Mass Limits

Parameter	Unit	Number of Samples	Limit Type	Compliant
Average Annual Flow	ML/yr	365	maximum	✓
Nitrogen Mass Load	kg/yr	52	maximum	✓
Phosphorus Mass Load	kg/yr	52	maximum	✓

FAECAL COLIFORMS

Target Median Faecal Coliforms was exceeded two times and 80th Percentile Faecal Coliforms exceeded eight times. Non-compliances were due to equipment faults and repairs combined with the significant rainfall events. 96% compliance with the Faecal Coliforms median and 85% compliance with the Faecal Coliforms 80th Percentile limits were achieved in the 2021-22 financial year.

Figure 19 – Maroochydore STP – Faecal Coliforms – Median





Figure 20 – Maroochydore STP – Faecal Coliforms – 80th Percentile



3.11 Murrumba Downs Sewage Treatment Plant

Table 19 – Murrumba Downs STP Release Targets

Parameter	Unit	Number of Samples	Target Type	Compliant
BOD	mg/L	52	long term 80th percentile	✓
			short term 80th percentile	✓ ¹
			maximum	✓
TSS	mg/L	52	long term 80th percentile	✓
			short term 80th percentile	✓
			maximum	✓
pH	pH units	52	range	✓
DO	mg/L	52	minimum	✓
Ammonia Nitrogen	mg/L	52	maximum	✓
TN	mg/L	52	long term 50th percentile	✓
			short term 50th percentile	✓
			maximum	✓
TP	mg/L	52	long term 50th percentile	✓
			short term 50th percentile	✓
			maximum	✓ ²
Faecal Coliforms	cfu/100 mL	260	median	✓ ³
			80th percentile	✓ ³

1. Short term 80th Percentile BOD was exceeded five times in the 2021-22 financial year. Please refer to the next page for further details.
2. Total Phosphorus Maximum was exceeded once in the 2021-22 financial year. Please refer to the next page for further details.
3. Faecal Coliforms Median was exceeded six times and 80th Percentile four times in the 2021-22 financial year. Please refer to the next page for further details

Table 20 – Murrumba Downs STP Volumetric Limits

Parameter	Unit	Number of Samples	Limit Type	Compliant
Dry Weather Flow	ML/d	234	maximum	✓ ¹
			average	✓
Volumetric Release	ML/d	365	maximum on any one day	✓

1. Dry Weather day exceeded due to the tail effects of a significant rainfall event.


Table 21 – Murrumba Downs STP Mass Limits

Parameter	Unit	Number of Samples	Limit Type	Compliant
BOD	kg/yr	52	annual load	✓
	kg/d		50th percentile load	✓
TN	kg/yr	52	annual load	✓
	kg/d		50th percentile load	✓
TP	kg/yr	52	annual load	✓
	kg/d		50th percentile load	✓

TOTAL PHOSPHORUS

Total Phosphorus Maximum was exceeded once following a severe wet weather event with 328mm of rain in the two weeks prior to the exceedance. Overall 98% compliance with the Total Phosphorus Maximum limit was achieved in the 2021-22 financial year.

Figure 22 – Murrumba Downs STP – Total Phosphorus – Maximum



FAECAL COLIFORMS

Target Median Faecal Coliforms was exceeded six times and 80th Percentile Faecal Coliforms exceeded four times. The UV disinfection system at Murrumba Downs STP was damaged during the February extreme wet weather event reducing disinfection system reliability. Parts were ordered and installed as quickly as possible to restore full capability. 88% compliance with the Faecal Coliforms median and 92% compliance with the Faecal Coliforms 80th Percentile limits were achieved in the 2021-22 financial year.

Figure 23 – Murrumba Downs STP – Faecal Coliforms – Median





Figure 24 – Murrumba Downs STP – Faecal Coliforms – 80th Percentile



3.12 Nambour Sewage Treatment Plant

Table 22 – Nambour STP Release Targets


Parameter	Unit	Number of Samples	Target Type	Compliant
TSS	mg/L	52	long term 80th percentile	✓
			short term 80th percentile	✓
			maximum	✓
pH	pH units	52	range	✓
DO	mg/L	52	minimum	✓
NH ₃ -N	mg/L	52	long term 50th percentile	✓
			maximum	✓ ¹
TN	mg/L	52	long term 50th percentile	✓
TP	mg/L	52	long term 50th percentile	✓
Faecal Coliforms	cfu/100 mL	52	median	✗ ²
			80th percentile	✗ ²

1. Ammonia maximum was exceeded once in the 2021-22 financial year. Please refer to the next page for further details.
2. Faecal Coliforms Median was exceeded 16 times and 80th Percentile 11 times in the 2021-22 financial year. Please refer to the next page for further details.

AMMONIA

Ammonia Maximum was exceeded once. Nambour STP utilises Membrane bioreactors to produce treated effluent. Caustic soda was discharged to the reactor during a membrane cleaning process causing a short-term reduction in ammonia removal. Overall 98% compliance with the Ammonia Maximum limit was achieved in the 2021-22 financial year.

Figure 25 – Nambour STP – Ammonia – Maximum



3.13 Noosa Sewage Treatment Plant

Table 23 – Noosa STP Release Targets

Parameter	Unit	Number of Samples	Target Type	Compliant
Faecal Coliforms	cfu/100 mL	52	maximum	✓
			80th percentile	✓

Table 24 – Noosa STP Mass Limits

Parameter	Unit	Number of Samples	Limit Type	Compliant
Average Annual Flow	ML/yr	365	median	✓
Nitrogen Mass Load	kg/yr	-	maximum	✓
Phosphorus Mass Load	kg/yr	-	maximum	✓

3.14 Redcliffe Sewage Treatment Plant

Table 25 – Redcliffe STP Release Targets

Parameter	Unit	Number of Samples	Target Type	Compliant
BOD	mg/L	52	long term 80th percentile	✓
			short term 80th percentile	✓
			maximum	✓
TSS	mg/L	52	long term 80th percentile	✓
			short term 80th percentile	✓
			maximum	✓
pH	pH units	52	range	✓
DO	mg/L	52	minimum	✓
Free Chlorine Residual	mg/L	52	maximum	✓
Faecal Coliforms	cfu/100 mL	260	median	✓ ¹
			80th percentile	✓ ¹

1. Faecal Coliforms Median was exceeded twice and 80th Percentile once in the 2021-22 financial year. Please refer to the next page for further details.

Table 26 – Redcliffe STP Mass Limits

Parameter	Unit	Number of Samples	Limit Type	Compliant
Average Annual Flow	ML/yr	365	maximum	✓
Nitrogen Mass Load	kg/yr	-	maximum	✓
Phosphorus Mass Load	kg/yr	-	maximum	✓

FAECAL COLIFORMS

Target Median Faecal Coliforms was exceeded twice and 80th Percentile Faecal Coliforms was exceeded once. UV system maintenance in October and a rain event of 127mm in May resulted in reduced disinfection system performance. 96% compliance with the Faecal Coliforms median and 98% Faecal Coliforms 80th Percentile limits were achieved in the 2021-22 financial year.

Figure 28 – Redcliffe STP – Faecal Coliforms – Median





Figure 29 – Redcliffe STP – Faecal Coliforms – 80th Percentile



3.15 South Caboolture Sewage Treatment Plant

Table 27 – South Caboolture STP Release Targets

Parameter	Unit	Number of Samples	Target Type	Compliant
BOD	mg/L	52	long term 80th percentile	✓
			short term 80th percentile	✓
			maximum	✓ ¹
TSS	mg/L	52	long term 80th percentile	✓ ²
			short term 80th percentile	✗ ²
			maximum	✓ ³
pH	pH units	52	range	✓
DO	mg/L	52	minimum	✓
Free Chlorine Residual	mg/L	52	maximum	✓
Faecal Coliforms	cfu/ 100 mL	260	minimum	✓ ⁴
			80th percentile	✓

1. BOD maximum was exceeded once in the 2021-22 financial year. Please refer to the next page for further details.
2. TSS Long term 80th Percentile was exceeded three times, Short term 80th Percentile was exceeded 17 times and TSS Maximum was exceeded twice in the 2021-22 financial year. Please refer to the next page for further details.
3. pH minimum was exceeded once in the 2021-22 financial year. Please refer to the next page for further details.
4. Faecal Coliforms Median and 80th Percentile were each exceeded twice in the 2021-22 financial year. Please refer to the next page for further details.

Table 28 – South Caboolture STP Mass Limits


Parameter	Unit	Number of Samples	Limit Type	Compliant
Average Annual Flow	ML/yr	366	maximum	✓
Nitrogen Mass Load	kg/yr	-	maximum	✓
Phosphorus Mass Load	kg/yr	-	maximum	✓

Exceedances

BOD

BOD Maximum was exceeded once following an extreme rainfall event where 840mm of rain was recorded at the STP. Overall 98% compliance with BOD Maximum limits was achieved in the 2021-22 financial year.


Figure 30 – South Caboolture STP – BOD – Maximum



TSS

TSS Long term 80th Percentile was exceeded three times. Short term 80th Percentile was exceeded 17 times and TSS Maximum was exceeded twice. Long Term 80th Percentile TSS non-compliance from the previous financial year continued to be reported due to the calculation method of this compliance measure, even though compliant TSS results were being measured onsite. Further the significant rainfall events have contributed to TSS non-compliance. An upgrade project currently in delivery phase will provide the plant with an improved wet weather flow handling capability that will improve TSS compliance and reduce the need for tank cleaning works. Overall TSS Long term 80th Percentile was compliant 94%, Short term 80th Percentile was compliant 67% and TSS Maximum was compliant 96% of the time in the 2021-22 financial year.


Figure 31 – South Caboolture STP – TSS – Maximum



pH

pH was outside the required range once. All STP equipment and processes were within normal ranges during this period therefore this exceedance is believed to be due to a change in a raw sewage characteristic. Overall 98% compliance in pH targets was achieved in the 2021-22 financial year.

Figure 34 – South Caboolture STP – pH – Minimum



Faecal Coliforms

Target Median Faecal Coliforms and 80th Percentile Faecal Coliforms were each exceeded twice due to wet weather events with 166mm over 3 days in December 2021 and 805mm over one day in February 2022. 96% compliance with the Faecal Coliforms median and Faecal Coliforms 80th Percentile limits were achieved in the 2021-22 financial year.

Figure 35 – South Caboolture STP – Faecal Coliforms – Median





Figure 36 – South Caboolture STP – Faecal Coliforms – 80th Percentile



3.16 Woodford Sewage Treatment Plant

Table 29 – Woodford STP Release Targets

Parameter	Unit	Number of Samples	Target Type	Compliant
BOD	mg/L	52	long term 80th percentile	✓
			short term 80th percentile	✓
			maximum	✓ ¹
TSS	mg/L	52	long term 80th percentile	✓
			short term 80th percentile	✓
			maximum	✓ ²
pH	pH units	52	range	✓
DO	mg/L	52	minimum	✓
Free Chlorine Residual	mg/L	52	maximum	✓
Faecal Coliforms	cfu/100 mL	260	median	✓
			80th percentile	✓

1. BOD Maximum was exceeded once in the 2021-22 financial year. Please refer to the next page for further details.
2. TSS Maximum was exceeded once in the 2021-22 financial year. Please refer to the next page for further details.

Table 30 – Woodford STP Mass Limits


Parameter	Unit	Number of Samples	Limit Type	Compliant
Average Annual Flow	ML/yr	365	maximum	✓
Nitrogen Mass Load	kg/yr	-	maximum	✓
Phosphorus Mass Load	kg/yr	-	maximum	✓

Exceedances

BOD

BOD Maximum was exceeded once due to the significant wet weather event with 102mm of rain the in the preceding week, combined with a failed balance tank mixer causing solids accumulation. Overall 98% compliance with BOD Maximum limits was achieved in the 2021-22 financial year.


Figure 37 – Woodford STP – BOD – Maximum



TSS

TSS Maximum was exceeded once for the same reasons as the BOD exceedance described above. Overall TSS Maximum was 98% compliant in the 2021-22 financial year.

Figure 38 – Woodford STP – TSS – Maximum





4

DEFINITIONS
AND LEGEND

4. Definitions and Legend

Definitions of acronyms, units of measurement and legends throughout this performance report are defined below.

Table 31 – Acronyms and Definitions

Acronym	Term	Definition
BOD	biochemical oxygen demand after 5 day test	The amount of dissolved oxygen needed by aerobic organisms to break down organic material.
BNR	biological nutrient removal	A biological process used for nitrogen and phosphorous removal from sewage.
DES	Department of Environment and Science	
DO	dissolved oxygen	Gaseous oxygen that is mixed in water and is available to aquatic organisms for respiration.
<i>E. coli</i>	<i>Escherichia coli</i>	Used as an indicator of pathogenic organisms that may cause diseases.
IDEA	intermittent decanted extended aeration	A three stage wastewater treatment process that involves aeration, settling and decanting.
NH₃ – N	ammonia nitrogen	A chemical compound that is removed in order to maintain the health of waterways. High levels can cause environmental issues such as eutrophication.
SBR	sequential batch reactors	A draw-and-fill biological treatment process that uses aerobic microorganisms to break down and treat wastewater.
TN	total nitrogen	The sum of nitrate, nitrite and ammonia in water. These are removed in order to maintain the health of waterways and prevent environmental issues such as eutrophication.
TP	total phosphorus	The sum of phosphorus compounds. These are removed in order to maintain the health of waterways and prevent environmental issues such as eutrophication.
TSS	total suspended solids	Total amount of solid particles that remain suspended within the wastewater.
UV	ultraviolet	A technology using radiation that disinfects wastewater.
	faecal coliform	Used as an indicator of pathogenic organisms that may cause diseases.
pH		A figure expressing the acidity or alkalinity of the water





Table 32 – Definition of Units

Units	Definition
µs/cm	micro-Siemens per centimetre
cfu/100 mL	colony forming units per 100 millilitre
kg/yr	kilograms per year
mg/L	milligrams per litre
ML	megalitres
ML/yr	megalitres per year
NTU	Nephelometric Turbidity Units



Unitywater

Serving you today,
investing in tomorrow.

-
-  unitywater.com
 -  **1300 086 489**
Emergencies and Faults 24 hours
Customer Service: 8am - 5pm,
Mon - Fri (except public holidays)
 -  Unitywater, PO Box 953, Caboolture QLD 4510
 -  Customer Service Counters 8.30am - 4.30pm,
Mon - Fri (except public holidays)
6 -10 Maud Street, Maroochydore QLD 4558
33 King Street, Caboolture QLD 4510

Unitywater has certification to
OH&S ISO 45001: 2018 Reg No 50000079
Environmental ISO 14001: 2015 Reg No 500000079
Quality ISO 9001: 2015 Reg No 500000079
Food Safety ISO 22000: 2018 Reg No 500000079

